



- NOTES:
1. Height above sea level of the escalator place should not be higher than 1000m. In case of doubt, please contact MP.
 2. If one of the following situations, the dimensions marked with * shall be extended 500mm:
 (1) 600 mm step width.
 (2) Double drive.
 (3) VVVF.
 (4) 220V and power exceeds 7.5 kW.
 3. Client should provide the intermediate support base, which can be made of reinforced concrete or metallic structure in right position, in case of horizontal distance L higher than 15 m.
 4. The requirements of escalators and building interfaces must be according with the national standards (EN115-1:2008+A1:2010). In case of doubt, please contact MP.